



MIDWEST CANVAS CORP.

CONSTRUCTION PRODUCTS DIVISION

PHONE: 518 892 9992

dunphymidwest@gmail.com

FAX: 518 271 2536

October 2011

Dear Construction Products Customer;

This is to certify that all Midwest Canvas Corporation's insulating blankets have been tested for Effective Thermal Resistance using ASTM: C518 test method.

ASTM: C518 thermal resistance test

Calibrated test equipment:

Mitutoyo Calipers model#39247-35 ID MM160-008

Sartorius Balance model 1384 ID MM170-004

Thermometer range -10 to 260 C

Holometrix Heat Flow Meter mode Rapid K s# TCT-3

Tested with a 3-inch airspace

Product: MCF7.48

Effective R value: 7.48

Testing performed by: Stork Twin City Testing Corp., St. Paul, Mn. Project: 97-002.5 9/97

Tim Dunphy
National Sales Manager
Midwest Canvas Corp.

N.B.: PRICING SUBJECT TO CHANGE WITHOUT NOTICE.

