



# MIDWEST CANVAS CORP.

## CONSTRUCTION PRODUCTS DIVISION

PHONE: 518 892 9992

dunphymidwest@gmail.com

FAX: 518 271 2536

November 2012

Dear Construction Products Customer;

This is to certify that all Midwest Canvas Corporation's insulating blankets have been tested for Effective Thermal Resistance using ASTM: C518 test method.

ASTM: C518 thermal resistance test  
Calibrated test equipment:  
Mitutoyo Calipers model#39247-35 ID MM160-008  
Sartorius Balance model 1384 ID MM170-004  
Thermometer range -10 to 260 C  
Holometrix Heat Flow Meter mode Rapid K s# TCT-3

PRODUCT: MCF5.61 EFFECTIVE R VALUE: 5.61

Testing performed by: Stork Twin City Testing Corp., St. Paul, Mn. Report #3018 98 66986.1 1998

Tim Dunphy  
National Sales Manager  
Midwest Canvas Corp.

**N.B.: PRICING SUBJECT TO CHANGE WITHOUT NOTICE.**

